

Government of Tripura
Animal Resources Dev. Department
P. N. Complex, Agartala.

No. F. 4-289/ARDD/STY/2011/Vol.-I

Dated, Agartala, the 9th Jan' 2015.

Notice Inviting Tender


Tender in sealed cover is hereby invited by the undersigned on behalf of the Governor of Tripura from the bonafied & resourceful manufacturing Companies/local authorized Distributors/Dealers/Stockiest of the manufacturing Companies for supply, installation & Commissioning of 10(ten) nos (initially) fixed type 5 KVA Diesel Generator , single phase , 230/240 Volts,1500 RPM, Air cooled Diesel Generator Set with suitable Engine of reputed brand having a canopy system and appropriate Battery etc. including Test & Trial run with full load condition for different Block level Brooder House (BLBHs) of the State .

The details specification of D.G. Set, and terms & conditions of tender will be available from the Office of the undersigned (Store Section) on all working days till **6th Feb, 2015** & will also be available in the Official website of Tripura www.tripura.gov.in/www.arddtripura.nic.in/www.tripurainfo.com .

The last date for submission of tender in sealed cover envelop superscribe "Tender for supply, installation and commissioning of 10(ten) nos. initially 5 K.V.A. Diesel Generator set" through Speed Post/Registered Post/Courier Service, addressed in favour of the Director, Animal Resources Dev. Dept; P. N. Complex, Agartala – 799006, Govt. of Tripura, is **on or before 1 p.m. of 6th Feb, 2015.**

The tenders will be opened on the next working day, if possible. The tenderers or their representative may remain present at the time of opening.

The Director, Animal Resources Dev. Dept. reserves the right to accept or reject any/all tender and extend the date of receipt of tender without assigning any reason thereof.


(Dr. Dharmeswar Das) 9.1.15
Director,
Animal Resources Dev. Department
Government of Tripura

TERMS & CONDITIONS

Terms & conditions for supply, installation and commissioning of 10 nos. of 5 K.V.A Single Phase 230/240 Volts, 1500 RPM, Air cooled Diesel Generator set (fixed type) with suitable Engine of reputed brand having a canopy system and appropriate Battery etc. including Test & Trial run with full load condition to the block level Brooder House (BLBHs) under different Gaon panchayet areas of the State. The details specification is enclosed at Annexure-A.

1. The tenders will be received by speed post/registered Post/Courier services only in sealed cover envelop addressed to the "Director of Animal Resources Dev. Dept., Govt. of Tripura, P. N. Complex, P.O. kunjaban, Agartala - 799006, **on or before 1 p.m. of 6th Feb, 2015.**

Tenders received after the aforesaid date and hours shall be rejected. The Director of Animal Resources Dev. Dept. shall not be responsible for any postal delay.

2. On the top left side of the sealed tender, enquiry number & date, due date of opening of tenders and detail address along with phone, Fax and S.T.D code number of the tenderer should be mentioned for communication.

3. The interested bidders/tenderer shall submit the bids in 2 parts, namely '**Financial Bid**' and '**Technical Bid**'. The 2 bids should be put in 2 separate sealed envelopes indicating on the cover as to which one is the technical bid and other one is the financial bid. The 2 envelopes shall then be placed inside a large sealed cover and the same may be submitted.

The technical Bid shall contain all details regarding the items offered by the bidder, compliances of terms and conditions, submission of documents, products catalogues, earnest money etc. In other words everything except the rate offered. The technical bids will be opened first and if fulfilled all requirements of Tender and then short-listed the valid Tender.

The Financial bid shall contain only the rate offered by the successful bidders.

4. **Copy of the following self attested documents should be submitted along with the Technical bid of the tender: -**

(i) Up to date CST clearance certificate (in case of bidder from outside of Tripura).


(ii) Up to date valid Trade License & VAT clearance certificate in case of authorized local Distributors/stockiest/dealers of the manufacturing firms.

(iv) PAN Card.

(iii) Quality assurance certificate like ISI, BIS, ISO standard.

(v) Earnest money (EM) for an amount of **Rs 60,000/- (Rupees sixty thousand)** only drawn in favour of the Director, Animal Resources Dev. Dept. in the shape of fresh deposit at Call (D - Call) or Bank Demand Draft of any Scheduled Bank of India to be **deposited along with the technical bid for each Tender.**

Contd...P/2


Dr. DHARMESWAR DAS
Director of A.R.D.D.
Govt. of Tripura.

5. In case of un-successful tenderers the Earnest Money deposit (EMD) shall be released after finalization of the tender, while in case of successful tenderers/suppliers, the same (EMD) shall be released after deposition of security money (SM) .

6. **The bidder should have the service providing Unit in the State Capital** .This is required for carry out the repairing work if found any disturbances after expiry of warranty / guarantee period. The detail address, phone, fax of the service provider to be submitted in tech. bid of the tender. **In case of the selected bidder who is from outside of Tripura should obtain sale tax clearance certificate at the time of supplying the item.**

7. The rate should be quoted in Indian currency only and be typed both in figures and words clearly.

8. The rate should be included for supplying; installation & commissioning of D. G. Sets to 10 nos block level Brooder House (BLBHs) under different panchayet areas of the State.

9. VAT & Income tax will be deducted from the bill as per Govt. Rule .

10. 5% value of quantity must be deposited as Security Money (SM) in the shape of deposit at Call (D-Call) or Bank Demand Draft of any Scheduled Bank of India **within 15 days from the date of issue of the supply order**, failing which, Earnest money deposit (EMD) will be forfeited straight way and supply order will be cancelled. Security Money Deposit (SMD) of the successful supplier will be released after completion of full supply with satisfactorily.

11. The Provision of Guarantee/warranty for minimum 1(One) year should be kept from the date of supply after satisfactory trial run of the machine.

12. The selected bidder will supply the goods **within 60 (sixty) days** from the date of issue of the supply order. In case of failure to supply the ordered item/items in full within stipulated period, the Security money (SM) shall be forfeited without further correspondence. However, relaxation will be entertained only in special circumstances like natural calamities, war or any other situation beyond human control.

13. Payment of the successful tenderers/bidders shall be made by bill basis only after completion of satisfactory supply, installation & commissioning of the items. No advance payment will be entertained.

14. The supply order will be issued once/at a time or in phased manner as per requirement.

15. EM & SM will not be applicable in case of Govt. / Public Sector Undertakings. In that case they submit documentary evidence to that effect.

16. The tenderer, who is not a manufacturer or who quoted rate in favour of the manufacturer, shall furnish **a letter of authority from the manufacturer**. Such tenderer shall also furnish an undertaking that in the event of acceptance of rate he will supply the products of the manufacturer for which he quoted the rate.

17. No. Insurance charge is admissible and the successful tenderer/supplier will be responsible for any breakage, damage and loss in transit or on the way to destination.

Contd. - P/3


Dr. BHARMESWAR DAS
Director of A.R.D.O.
Govt. of Tripura.

18. Any default or breach of contract, shall lead to forfeiture of earnest money/security money deposits of the successful bidder. Besides, such action as may be considered appropriate by the Director of ARDD including black listing of the concerned bidders/firms for future supply.

19. Any legal issue relating to procurement & supply of 5 KVA D.G. Set. would be within the jurisdiction of High Court of Tripura, Agartala.

20. **The rates will remain valid up to 31st Dec, 2015.** No interim revision/Enhancement of rates will be entertained except imposition of any levy or increase in existing levy by the Government.

21. The Director of ARDD, Govt. of Tripura, Agartala reserves the right to terminate the contract or cancel the supply order at any time without notice and assigning any reason before expiry of the period

22. Director, the Dept. of ARD, Govt. of Tripura, reserves the right to accept or reject any/all tenders without assigning any reason thereof and tender may be accepted or rejected in part or in whole. The supply order may be issued in part or in full or may be rejected.

23. A duly signed copy of terms & condition of the Dept. of ARD to be returned by the tenderers as a token of acceptance of the Departmental terms & conditions.


(Dr. Dharmeswar Das) 9.1.15
Director,
Animal Resources Development.

Name of work: - Supply, Installation & Commissioning of 10 nos. 5 K.V.A Single Phase, 230/240 Volts, 1500-RPM range, Air cooled Fixed Diesel Generator Set (fixed type) with suitable Engine of reputed brand having a canopy system and appropriate Battery etc. including Test & Trial run with full load condition to the block Level Brooder Houses (BLBHs) in the earmarked R.D. Block of Tripura (List of places enclosed in Annexure-B) for the year 2014-15.

The detail specification of D. G. Set, accessories & works are as follows:-

Sl. No.	Description of the items & Specifications	Unit	Rate
Supply, Installation & Commissioning of D. G. Set			
1.	Supply of Fixed 5 KVA single phase, 230/240 volt, 1500 RPM range, Air cooled Diesel Generator set Canopy System noise level below 75db at 1.0 Mtr. as per the norms of CPCB-II with suitable Engine of reputed brand having a canopy system and appropriate battery etc. Details specification of the D.G. Set are as follows:-	For each sets	
i.	Rating - 5 K.V.A		
ii.	Frequency -50Hz		
iii.	Power Factor-0.8		
iv.	Phase -1		
v.	Volt- 230/240		
vi.	Governing class -G 2		
vii.	No. of Cylinder - 1.		
viii.	Alternator -H Class.		
Accessories for Installation & Commissioning			
2.	Ear-thing with G. I. Earth pipe 4.5 m long and 40 mm dia. with masonry enclosure on top etc. as required as per direction of the site Engineer.	For each Gen sets	
3.	Items required as extra for using salt and charcoal for pipe earth electrode.	For each Gen sets	
4.	Providing and fixing 4.06 mm dia. (8 SWG) G. I. Wire on Surface or in recess for loop ear thing.	Rate per meter	
5.	Supplying and fixing of ½" dia. polythene pipe (best quality) with necessary saddle, screw etc. as required.	Rate per meter	
6.	Supplying and fixing of M. S. clamp on wall including C - C work for fitting 63 amps D.P. change over switch.	For each Gen sets	
7.	Supplying and fixing of 63amps D.P. changeover/Main switch including drilling holes on the board/M.S. clamp connections etc. as required (Make-HAVEL's/HPL/L & T).	For each Gen sets	
8.	Supplying and drawing of 2 X 10 Sq.mm PVC insulated copper conductor cable (10sq.mm)(Make-FENOLEX/HAVELL'S, Polycab) including necessary connection etc. as required.	Rate per meter.	
7.	Diesel for each 5 KVA D.G. Set. for trial run of the machine.	30 lit. (approx.)for each set	


(Dr. Dharmeswar Das) 9.1.15
Director,
Animal Resources Dev. Department